

Notice of Violation of Colorado Primary Drinking Water Regulation, 5 CCR1002-11

The Colorado Department of Public Health and Environment (CDPHE) Water Quality Control Division has determined that the Operator in Charge has violated Regulation 11 sections 11.28(4)(c) and (v) and failed to correct a lack of Seals on the Access hatches for Tanks #1, #2 and #3. Also an unsealed opening on an old electrical wiring conduit box on the side of Well head #3, a broken electrical wire conduit that goes from the bottom of Tank 3 to the inside of its access hatch and has not developed an 'adequate' finished water storage tank inspection Plan. Therefore I must notify all Individuals served by the District of this violation and provide the following information.

The Violations have been in place since June 17, 2021.

Inadequately maintained storage tanks, identified through inspections, may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches. Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in public places or by distributing copies by hand

All issues have been resolved except for the small root intrusion in Tank #1, due to it being underground. This will be resolved when the contractor we use for cleaning our tanks, returns this fall.

This of course effects the entire population of the area served by Thunderbird Water but as I previously stated there is currently no Health issues with the water. I don't feel it is necessary to obtain other water supplies.

There is no action that is necessary to be taken at this time, however please notify anyone who uses the Water in Indian Creek, of these Violations.

This Notice will be on Our Website (thunderbirdwater.com), until the Violation has been resolved to the satisfaction of CDPHE.

If you require further information, please contact me at
Larry Morris
ph. 303-525-6835
5780 W. Sioux Dr. Sedalia, Co. 80135